




XXXXXXXXXX
XXXXXXXXXXXX

Found loose duct in attic and a **LOT** of excess flex duct. When everything was reconnected and made to be straight and tight, all areas were balanced properly.

Healthy Homes of La, LLC



Initial Reading upon arrival
07.07.2016

Job # Redact
 Performed by Bobby for:

Healthy Homes of La. LLC
 PO Drawer 3127
 West Monroe, La 71294
 Phone: 318-355-1918 Fax: 318-397-2123
 www.parksair.com bobby@parksair.com

Scale: 1 : 79
 Page 1
 Right-Suite® Universal 2017
 17.0.04 RSU10742
 2016-Jul-07 10:18:24
 ...bby\Desktop\Load Redact